



Accurex™

Patented Automatic Machine Health Diagnosis of Rotating Machinery



Financial crisis




Retirement




🌀 How staffed are production sites?



YESTERDAY



TODAY



🌀 How can we improve the efficiency of a CM program?




- Help expert users to prioritize their work
- Empower the rest of the staff:
 - Relieve the experts on less critical machines
 - Optimize the maintenance process
 - Easy check other machines

Help the Expert user

Focus on critical machines




Assets health



- OK
- Action required



1st level: Help the expert focus on critical machines



**Machine
Overall Health Status**



Immediate action required



Shorten control periodicity




No action required


Example @Kimberly Clark (paper industry)

**206 machines(pumps, fans...)
100% faults detected**

Automatic diagnostic



Expert



Empower the others

🌀 Help the rest of the staff to do something



- Assistance to diagnostic (<2 year experience)
- Take Immediate corrective actions on less critical machines without help of the expert – **Save time!**



- Take additional controls on suspicious machines between 2 periodic controls – **Save the machine!**
- Quick check-up on machines that are not part of the condition monitoring program – **Optimize maintenance**



1. Easy & reliable automatic setup



- Suitable for personnel of all skill levels:
Description of the machine kinematics

2. Instantaneous result



- Result on the spot, embedded in a portable device: interact with the machine
- **Based on a single measurement**



3. Need of 2nd level of diagnosis to guide the user



Details and recommendations per location



Slight defect



Defect to be monitored



Defect to be corrected

4 – Need a system that can be trusted




■ Confidence level indicator

- Can it be converted into action ?
- or just used as assistance to the diagnostic?

Identified Technical Solution



ONEPROD Experience in Artificial intelligence systems




Knowledge: ISO10816 and vibration analysis experience

If the vibration level conforms to the ISO10816 and there are no shocks on the machine, then this machine is healthy...




... if not: Scanning all symptoms on the machine



- Overall velocity vibration HIGH?
- Presence of shocks?
- Evolution compared to the previous measurement?
- *Bearing temperature HIGH?*
- ...

🌀 Symptom probability evaluation: smooth results


Symptom
Probability




“This symptom is most likely present”

**ISO10816 Alarm
Thresholds**

Example of defect



How it works



Examples of results

🌀 Sacramento waste water treatment (USA)





- A 15 HP motor driven pump was making an excessive amount of noise.
- the basic vibration bearing meter was not identifying that there was an issue...




🌀 Fault instantly confirmed at the first control

4-Pump-NDE



P08 (1/1)
P08


Accelerometer IEPE
12/02/2015 09:40:58



● 1-MT-Ax
● 1-MT-RH
● 1-MT-RV

● 2-MT-Ax
● 2-MT-RH
● 2-MT-RV


● 3-PP-Ax
● 3-PP-RH
● 3-PP-RV

● 4-PP-Ax
● 4-PP-RH
● 4-PP-RV



P08

P08/Sacramento Waste
P08


29.58 Hz
04/04/2016 18:00:11
12/12 point(s)





Bearing defect : wear / lu...

Bearing wear to be corrected: lubricate the component and measure again. If lubrication is not in cause, replace the bearing on component Pump as soon as possible.



Component / Location	Severity
Pump / 4-Pump-NDE	



🌀 Bearing defect confirmed



OK After repair



P08-2

P08-2/Sacramento Waste

P08-2

29.58 Hz 04/04/2016 18:01:44 12/12 point(s)

Good overall state for component 'Electric motor'.
Good overall state for component 'Pump'.



Blower - Misalignment detected and confirmed

The Falcon SMART was used recently to test (3) Gardner-Denver blowers at the Yadkinville, NC Wastewater Treatment facility.




The Falcon reported that one of these blowers had a misalignment problem.

Expertise Report

Filter: Equipment name (+) | Tree order (+)

Location	Yadkin County WTP	Fixed speed	
Designation	...		
Equipment	G-D Blower		
Designation	...		
Abbreviation	GDB1		
Serial No			
Model			
Periodicity (d)	Normal 60 Alarm 15		
Previous Advice	Condition		Rotation Speed



Date: 01/04/2015 13:18:35 **FAIR** Health is not acceptable for a long time service.

Speed: 69.6 Hz / 3577 rpm
 Author: sridle
 Instrument sn: -10461
 Sensor:
 Connector:

Condition: DfCnd

Diagnosis & Recommendation Parameters sheet

Diagnosis

Overall state still acceptable for the component 'Electric motor'.
 Good overall state for component 'Pump'.

Misalignment to be corrected Confidence=***



Structural resonance to be watched Confidence=**

Unbalance to be watched Confidence=***

Recommendations

Misalignment to be corrected as soon as possible.
 Location "Motor-DE" slight
 Location "Motor-NDE" to be corrected
 Structural resonance that amplifies vibration imbalance at rotational frequency.
 Slight structural resonance that amplifies vibration imbalance at rotational frequency.
 Location "Motor-NDE" to be watched
 Unbalance to be watched. A correction is conceivable during a planned shutdown.
 Slight Unbalance: component Pump might require closer monitoring.
 Location "Motor-DE" to be watched

IP1.jpg





OK after alignment

This soft foot was corrected, and the machine aligned to within VibrAlign specifications.

VIBRALIGN	VIBRALIGN		OneProd Brand of ACOEM
	Issue A	page 1 / 1	

Expertise Report

Filter: Equipment name (+) \ Tree order (+)

Location	Yadkin County WTP\Blower Building\	
Designation		
Equipment	G-D Blower	Fixed speed
Designation Abbreviation	B3	
Serial No		
Model		
Periodicity (d)	Normal 60 Alarm 15	



Previous Advice	Condition	Rotation Speed
15/05/2015 09:06:59	FAIR	DfCnd 59.6 Hz 3577 rpm

Date: 05/06/2015 08:57:50 **EXCELLENT**
 Health is excellent (no default, low vibration levels).

Speed 59.6 Hz / 3577 rpm
 Author sridle
 Instrument sn - 10461
 Sensor
 Connector

Condition DfCnd



Diagnosis & Recommendation

Diagnosis

Good overall state for component 'Electric motor'.
 Good overall state for component 'Pump'.

Recommendations
 No action required

Parameters sheet



🌀 Screw Compressor – Liberté - CANADA




1-Motor-NDE

📍 MYCOM Liberté (1/1)

🏠 MYCOM Liberté

Accelerometer IEPE 31/05/2018 14:51:40



	Ax(Y)	RH(Z)	RV(X)	
NG Vit Vib	0.092	0.148	0.056	inch/s
NG Acc	2.77	4.13	1.75	g
Facteur Def	4.92	5.58	4.58	DEF

MYCOM Liberté

MYCOM Liberté/CIMCO/Liberté yagour/MYCOM Liberté



Operating Point

1-MT-Ax	2-MT-Ax	3-LC-Ax	4-LC-Ax
1-MT-RH	2-MT-RH	3-LC-RH	4-LC-RH
1-MT-RV	2-MT-RV	3-LC-RV	4-LC-RV
5-LC-Ax	6-LC-Ax		
5-LC-RH	6-LC-RH		
5-LC-RV	6-LC-RV		

MYCOM Liberté

📍 MYCOM Liberté/CIMCO/Liberté yagour

🏠 MYCOM Liberté

3585 CPM 20/10/2018 15:19:25 19/19 point(s)



Overall state not acceptable for the component 'Moteur électrique'.

Overall state still acceptable for the component 'Compresseur à lobes'.

Type	Severity	Confidence
Bearing defect : wear / l...		★★★★
Shock / Modulation		★★★★




Screw Compressor – Liberté – Confirmed by the expert



f0:Rot Speed 59.75Hz
6313 [SKF] I1:294.56Hz E1:183.43Hz
B1:243.18Hz C1:22.7Hz

Ok – after bearing change

1-Motor-NDE
MYCOM Liberté (1/4)
Liberte



Accelerometer IEPE 31/05/2016 17:19:18

	Ax(Y)	RH(Z)	RV(X)	
NG Vit Vib	0.042	0.108	0.064	inch/s
NG Acc	0.665	1.44	0.514	g
Facteur Def	2.61	2.98	2.25	DEF
Spectre BF	✓	✓	✓	g
Spectre MF	✓	✓	✓	g
Spectre HF	✓	✓	✓	g

MYCOM Liberté
Liberte/CIMCO/Liberté yagour
Liberte



3585 CPM 20/10/2016 15:20:01 19/19 point(s)

← Previous

Next →

Etat global bon pour le composant 'Moteur électrique'.
Etat global bon pour le composant 'Compresseur à lobes'.


Detect

Return

20/10/2016
15:20



Know the limits!



■ Most common machines (about 80%)

- Electric motors, Pumps, Fans, Compressors (Centrifuge, Lobed), Gearboxes, Rollers
- **Speed limit**
 - >120 RPM (ISO10816)
 - Difficult automatic identification of the rotation speed for low speed machines (field testing results: < 300RPM, Level 1 OK 100%, Level 2 not always available)

■ Most common defects (about 80%)

- Unbalance, Misalignment, Bearing and lubrication, Mounting, clearance, friction, Gear defects, Cavitation



Patent publication on the confidence level



US 20160041070A1

(19) **United States**

(12) **Patent Application Publication** (10) **Pub. No.:** US 2016/0041070 A1
(43) **Pub. Date:** Feb. 11, 2016

(54) **AUTOMATIC ROTATING-MACHINE FAULT DIAGNOSIS WITH CONFIDENCE LEVEL INDICATION** (52) **U.S. CL**
CPC *G01M 99/008* (2013.01); *G01M 99/005* (2013.01); *G06N 7/005* (2013.01)

(71) Applicant: **01dB-METRAVIB, Société par Actions Simplifiée**, Limonest (FR)

(57) **ABSTRACT**

(72) Inventors: **Bertrand Wascat**, Ecully (FR); **Guillaume Lavaure**, Lyon (FR); **Kamel Mekmoucha**, Grenoble (FR); **Patrick Labeyrie**, Dardilly (FR); **Thierry Mazoyer**, Massieux (FR)

Automatic fault diagnosis is performed on vibration data sensed from a machine. A set of faults to screen for is identified from the machine configuration. For each fault there are characteristic symptoms. For each characteristic symptom, there is a corresponding indication used to diagnose the symptom. The indications are based on analyses of the current vibration data. The diagnosed symptoms have weights assigned according to a Bayesian network, and are used to derive a Bayesian probability for the fault. A fault having a Bayesian probability exceeding a threshold value is identified as being present in the machine. For each fault a confidence level is derived. The confidence level for a first fault is based on a similarity between characteristic symptoms for the first fault and characteristic symptoms for each one of the other faults being screened.

(73) Assignee: **01dB-METRAVIB, Société par Actions Simplifiée**, Limonest (FR)

(21) Appl. No.: **14451,777**


(22) Filed: **Aug. 5, 2014**

Publication Classification

(51) **Int. Cl.**
G01M 99/00 (2006.01)
G06N 7/00 (2006.01)

Publication n°: 20160041070

Automatic Rotating-Machine Fault Diagnosis With Confidence Level Indication



Local representative



Represents OneProd in Sweden!



Some Swedish customers to systems with integrated Accurex™ technology

- **Tekniska Verken, Linköping**
- **SSAB**
- **SKF**
- **Strukton Rail**
- **BMUTEk**
- **Södra Woods, Mönsterås**
- **Bergkvist I Insjön**
- **Volvo cars**
- **And others...**